CM4371-50 CM4373-50 CM4375-50 AC/DC CLAMP METER







Contents

Nota Chec Optic Safe	tions cking ons ty Info	Package Contentsormation	3 7 8 11
1_	Ov	erview	19
	1.1 1.2	Product Overview and Features Part Names	
2	Ma	king Measurements	21
	2.1 2.2	Inspection Before Measurement Installing Batteries and the Z3210 Wireless Adapter Installation procedure	22
	2.3	Use of Test Leads	28
Conte	nts		
	2.4	Current Measurement Manual hold, automatic hold Switching the ranges Filter function Maximum value, minimum value, average, and peak value Inrush current (inrush)	35 39 40
	2.5	Various Other Measurement Functions	
	2.6	LCD Backlight, Automatic Power Save (APS)	
	2.7 2.8	DC High V Probe Mode Wireless communications function	
	2.0	Using GENNECT Cross	52
	2.9	(Excel direct input function, HID function) Rotary Switch Combinations	
3	Spe	ecifications	61
	3.1 3.2 3.3	General SpecificationsInput Specifications, Measurement SpecificationsAccuracy table	65
		· · · · · · · · · · · · · · · · · · ·	



Contents 4 **Maintenance and Service** 107 Troubleshooting......107 Error and Operation Displays109 4.2 Cleaning110 5 **Appendix** 111 Voltage Detection Function.....111 Example of Use113 Index 115 **Warranty Certificate** 119

HIOKI CM4371C961-02

iii



Introduction

Thank you for choosing the Hioki CM4371-50/CM4373-50/CM4375-50 AC/DC Clamp Meter. To ensure your ability to get the most out of this instrument over the long term, please read this manual carefully and keep it available for future reference.

Read the separate document "Operating Precautions" carefully before using the instrument.

Latest edition of instruction manual

The contents of this manual are subject to change, for example as a result of product improvements or changes to specifications.

The latest edition as well as multilingual editions of the manual (in Chinese, French, German, Italian Korean, and Spanish) can be downloaded from Hioki's website.



Product registration

Register your product in order to receive important product information.



Introduction

Target audience

This manual has been written for use by individuals who use the product in question or who teach others to do so. It is assumed that the reader possesses basic electrical knowledge (equivalent to that of someone who graduated from the electrical program at a technical high school).

Trademarks

- Excel is a trademark of the Microsoft group of companies.
- The Bluetooth[®] word mark and logos are registered trademarks owned by Bluetooth SIG, Inc. and any use of such marks by Hioki E.E. Corporation is under license. Other trademarks and trade names are those of their respective owners.



Notations

Safety notations

In this document, the severity levels of risk and hazard are classified as follows.

▲ DANGER	Indicates an imminently hazardous situation that, if not avoided, will result in death or serious injury.		Indicates an action that must not be performed.
≜WARNING	Indicates a potentially hazardous situation that, if not avoided, could result in death or serious injury.	0	Indicates an action that must be performed.
 ∴ CAUTION	Indicates a potentially hazardous situation that, if not avoided, could result in minor or moderate injury or potential risks of damage to the supported product (or to other property).	A	Indicates a high-voltage hazard. Failure to verify safety or improper handling of the instrument could lead to electric shock, burn injury, or death.
IMPORTANT	Indicates information or content that is particularly important from the stand point of operating or maintaining the instrument.	Â	Indicates the presence of a hazard caused by a strong magnet. The product could interfere with the proper operation of electronic medical devices such as pacemakers.

3

Notations

Symbols shown on the instrument

\triangle	Indicates the presence of a potential hazard. For more information about locations where this symbol appears on instrument components, see the "Operating Precautions" (p. 12) and the accompanying document entitled "Operating Precautions."
A	Indicates that a dangerous voltage is generated from this terminal.
Indicates that the product can be attached or detached while the circuit is live.	
	Indicates the instrument is protected throughout by double insulation or reinforced insulation.
\sim	Indicates alternating current (AC).
Indicates direct current (DC).	
Indicates the grounding terminal.	



Symbols for various standards



Indicates that the product is subject to the Waste Electrical and Electronic Equipment (WEEE) Directive in EU member nations.



Indicates that the product complies with standards imposed by EU directives.

Screen display

The instrument screen displays the alphanumeric characters as follows.



Notations

Accuracy labeling

Instrument accuracy is expressed by defining a percentage of the reading, a percentage of full scale, a percentage of the setting, or a limit value for errors in terms of digits.

Reading (display value)	Indicates the value displayed by the instrument. Limit values for reading errors are expressed as a percentage of the reading ("% rdg").
Full scale (maximum display value)	Indicates the maximum display value for each measurement range. Measurement range values for the instrument indicates that maximum display value. Limit values for full-scale errors are expressed as a percentage of full scale ("% f.s.").

Other notations

(p.)	Indicates the page number to reference.
*	Indicates additional information is described below.
CM4371-50	Indicates that the item is applicable to the CM4371-50 only.



Checking Package Contents

When you receive the instrument, inspect it to ensure that no damage occurred during shipment. Pay particular attention to included accessories, panel keys, and terminals. If you find any damage or discover that the instrument does not perform as indicated in its specifications, please contact your authorized Hioki distributor or reseller.




Options

Options

The options listed below are available for the instrument. To order an option, please contact your authorized Hioki distributor or reseller.


Options are subject to change. Check Hioki's website for the latest information.

Connection cables





Options



Options

Carrying cases

The instrument, test leads, and the instruction manuals can be accommodated.

C0203 Carrying Case



C0207 Carrying Case



Z3210 Wireless Adapter



Connecting the Z3210 to the instrument enables the wireless communication function.


See "2.8 Wireless communications function" (p.52).



Safety Information

Measurement categories

The instrument conforms to the safety requirements for CAT III 1000 V and CAT IV 600 V measuring instruments.



11

Operating Precautions

Operating Precautions

Observe the following precautionary information to ensure that the instrument can be used safely and in a manner that allows it to perform as described in its specifications. Carefully read the separate document entitled "Operating Precautions" before use. Use of the instrument should conform not only to its specifications, but also to the specifications of all accessories, options, and other equipment in use.

▲ DANGER

■ Do not touch the section beyond the barrier during operation.

Failure to do so could cause the operator to experience an electric shock. See "1.2 Part Names" (p.20).





Doing so can cause overheating of the sensor, resulting in bodily injury, fire, or damage to the instrument.

See "Frequency derating characteristics" (p.68).

The maximum measurement current varies with the frequency, and the current that can be measured continuously is limited. Operating the instrument at less than this limitation is referred to as derating.



A DANGER

Inspect the instrument and verify proper operation before use.



Use of the instrument while malfunctioning could result in serious bodily injury. If you find any damage, contact your authorized Hioki distributor or reseller. See "2.1 Inspection Before Measurement" (p.21).

■ Confirm that the white portion (insulation layer) inside the cable is not exposed.

Using the instrument with a color inside its cable exposed could cause the operator to experience an electric shock.

13

Operating Precautions

MARNING

- Do not allow the instrument to get wet.
- Do not take measurements with wet hands.

Failure to do so could cause the operator to experience an electric shock.



■When using the instrument while connected to test leads, do not make measurements that exceed either of the ratings indicated on the instrument or on the test leads, whichever is lower.

Using the instrument to make measurements that exceed either rating could cause the operator to experience an electric shock.

14

Operating Precautions

IMPORTANT



- Do not allow any foreign object to be caught between the facing core surfaces of the jaws.
- Do not scratch the facing core surfaces of the jaws.



- Do not touch the facing core surfaces of the jaws with your fingers.
- Do not insert any foreign object into the gap of the jaws.



- Do not drop the instrument.
- Do not subject the instrument to any shock.

Doing so may adversely affect the measurement accuracy and open/close operation.

Clamp the instrument around only one conductor. Clamping the instrument around two or more of conductors in a bundle prevents the instrument from measuring any current regardless of whether the measurement target is a single-phase or three-phase circuit.



Operating Precautions

L4937 Magnetic Adapter Set / 9804 Magnetic Adapter (optional)

A DANGER

- People with electronic medical devices such as pacemakers should not use the magnetic adapter.
- Keep the magnetic adapter away from the body.

Failure to do so may affect proper operation of the electric medical devices, presenting a hazard to human life.

16

Operating Precautions

ACAUTION

- Do not drop the magnetic adapter.
- Do not subject the magnetic adapter to mechanical shock.

Doing so could damage the magnetic adapter.

■ Do not use the magnetic adapter in locations where it may be exposed to rainwater, dust, or condensation.



exposed to rainwater, dust, or condensation.Doing so could decompose or deteriorate the magnetic adapter. In addition,

- diminished magnetic adhesion cause the instrument to drop, resulting in damage to the instrument.

 Do not bring the magnetic adapter near magnetic storage devices, such as floppy disks, magnetic cards, prepaid cards, or magnetized
- tickets.

 Do not bring the magnetic adapter near precision electronic equipment, such as computers, TV screens, or electronic wrist watches.

Doing so could damage such devices or data stored in them.



1.1 Product Overview and Features

This instrument is a clamp meter that can perform true RMS measurement of current simply by clamping it around a circuit. In addition to current, it can measure voltage, frequency, rush current, resistance, diode, capacitance, temperature, and AC power. Installing the Z3210 Wireless Adapter (optional) to the instrument allows your mobile device to display waveforms and measure harmonics.


Measurement function list

A+V VA	DC current and DC voltage, DC power		
NCV	Electric charge detection CM4371-50 CM4373-50		
TEMP	Capacitance, temperature		
→ Ω →	Continuity check, resistance, diode		
$_{ m AUTO}^{==\cdot\sim}{ m V}$	Automatic AC/DC, AC voltage, DC voltage, AC+DC voltage, frequency		
≕.∼ AUTO A	Automatic AC/DC, AC current, DC current, AC+DC current, frequency		

19

Part Names

1.2 Part Names



2

Making Measurements

2.1 Inspection Before Measurement

Check	Inspection details	Check	Inspection details
	The battery cover is closed and its screw has been securely tightened.	,	
	measurement terminals (p.20). The test leads are not broken (p.44). RANGE + RANGE + RANGE AUTO A		The instrument is neither damaged nor cracked.
			RANGE + PASSES PASS AND AND GREET PASSES PAS

21

Installing Batteries and the Z3210 Wireless Adapter

2.2 Installing Batteries and the Z3210 Wireless Adapter

Installing the Z3210 to the instrument enables the wireless communications function. (p.52) Before using the instrument for the fist time, insert two LR6 Alkaline batteries or two fully charged HR6 Nickel-metal hydride batteries.

MARNING

■ Before removing the battery cover, remove the instrument from an object under measurement and set the rotary switch to the OFF position.



Failure to do so could cause the operator to experience an electric shock. When the instrument is clamped around the object under measurement, the battery contact terminals are regarded as high-voltage parts.

22

Installing Batteries and the Z3210 Wireless Adapter

MARNING

■ After replacing the batteries or installing/removing the Z3210 Wireless Adapter, install the battery cover and tighten the screw, then use the instrument.



Use of the instrument with the battery cover removed could result in bodily injury.

■ Secure the battery cover with the screw attached to the instrument at the time of shipment.

If you have lost the screw or find that the screw is damaged, please contact your authorized Hioki distributor or reseller.



A CAUTION

- Do not mix batteries of different ages or types.
- Do not use a battery whose recommended service life has expired.
- Do not reverse the battery polarity.
- Do not leave the exhausted batteries in the instrument.

Doing so may cause the batteries to leak, damaging the instrument.

- Use the specified type of batteries only (LR03 Alkaline batteries or HR03 Nickel-metal hydride batteries).
- Remove the batteries when the instrument is not in use for an extended period of time.

Doing so may cause the batteries to leak, damaging the instrument.

■ Before handling the Z3210, eliminate static electricity on your body by touching any metallic part, such as a doorknob.

Failure to do so may cause static electricity to damage the Z3210.

- When the
 mark blinks, the batteries will be exhausted. Replace the batteries with new ones in good time. The instrument may be turned off when the display is backlighted or the buzzer sounds. After use, be sure to turn off the instrument.
- · Dispose of the batteries in accordance with local regulations.

24

Installing Batteries and the Z3210 Wireless Adapter

Nickel-metal hydride batteries

A CAUTION



■ When using the instrument, insert two LR6 Alkaline batteries or two fully charged HR6 Nickel-metal hydride batteries.

The instrument powered by nickel-metal batteries will indicate an inaccurate remaining-battery level; however, it can be used without any trouble even with such batteries inserted. See the continuous operating time below.

For CM4371-50

- · When two LR03 Alkaline batteries are used Approx. 40 hours (without the Z3210 installed) Approx. 20 hours (with the Z3210 installed, in wireless communication)
- · When two LR03 nickel-metal hydride batteries (750 mAh capacity each) are used Approx. 40 hours (without the Z3210 installed)


Approx. 25 hours (with the Z3210 installed, in wireless communication)

Visit an FAQ page on Hioki's global website for more information about nickel-metal hydride batteries that Hioki has guaranteed to work.

Valuetesters.com

Installation procedure

Read the precautions before performing the procedure. (p.22)



NO

Do not turn any screws except the battery cover screw.

After removing the battery cover, you will find three screws, which are used to adjust measured values. Do not turn them because the instrument will not be able to perform measurement accurately.

26

Installing Batteries and the Z3210 Wireless Adapter

- 1 Remove the instrument from an object under measurement and set the rotary switch to the OFF position.
- 2 Loosen the screw and remove the battery cover.
- 3 Remove the old batteries (when replacing the batteries).
- Install fresh batteries, observing the correct polarity.
 When installing the Z3210 Wireless Adapter, go on to step 5.
 When not installing the Z3210 Wireless Adapter, go on to step 7.
- 5 Remove the protective cap from the instrument.
- Install the Z3210 Wireless Adapter, observing the correct orientation.
- 7 Reattach the battery cover and tighten the screw.



2.3 Use of Test Leads

The L9300 Test Lead (accessory) or the L9207-10 Test Lead (optional) is used for measurement. Depending on measurement locations, use Hioki's optional measurement cables. See "Options" (p.8)

MARNING



■When using the instrument, use the test leads and options specified by Hioki.

Using test leads and options other than those specified could cause bodily injury or short circuit accidents.

- ■When measuring the power line voltage, use test leads that satisfy the following conditions.
 - IEC 61010 or EN 61010 safety standard-compliant



- Rated for measurement category III or IV
- With the rated voltage higher than voltage being measured
 Failure to do so could cause the operator to experience an electric shock.
 The optional test leads for this instrument comply with the EN 61010 safety standard. Observe the measurement category and rated voltage indicated on the test leads during use.

28

Use of Test Leads

A CAUTION



■ Do not bend the cables at temperatures of 0°C or lower. Do not pull on the cables.

The cables can become rigid. Doing so could damage the insulation or cause a wire break, resulting in an electric shock.

29

Use of Test Leads

L9300 Test Lead (accessory)

See the precautions in "Use of Test Leads" (p.28) as well.

WARNING

■ Use the test leads with the correct measurement category displayed.



■ Do not use the test leads if the metal pin is bent or the protective finger guard does not slide properly.


Doing so could cause short circuit accidents.




Switching the measurement category

1 Unlock the protective finger guard.

Rotate the grip to unlock, moving the \triangleright mark along the guide line.




2 Slide the protective finger guard.



31

Use of Test Leads

3 Lock the protective finger guard.



Perform the above steps to switch over III or IV as well.

2.4 Current Measurement

1 Rotate the rotary switch.




2 Hold down for 1 s.



IMPORTANT

Always perform zero adjustment to perform accurate measurement.



3 Clamp the instrument around the wire.



33

Current Measurement

Frequency detection range for AC current

CM4371-50	20.00 A range	4.00 A or more
CIVI437 1-50	600.0 A range	20.0 A or more
CM4373-50	600.0 A range	40.0 A or more
CIVI4373-50	2000 A range	200 A or more
CM4375-50	_	5.0 A or more

DC voltage polarity check (p.59)

If the measured value is negative, the buzzer will sound and the display will be backlighted in red. (threshold: -10 A)




Manual hold, automatic hold



HOLD The measured value freezes.

Press the **HOLD** key again to disable the hold function.



The measured value freezes automatically.

Holding down the \mbox{HOLD} key for 1 s to disable the automatic hold function.

35


Current Measurement

Automatic hold conditions

Displayed value will freeze when the following two conditions are satisfied at the same time:

- When the measured value fluctuation stabilizes within the fluctuation range described in the table on the next page.
- When the measured value exceeds the threshold value described in the table on the next page (voltage, current).

When the measured value is less than the threshold value described in the table on the next page (resistance, continuity check, diode).



Suppose that the measured value has fallen below (voltage, current) or exceeded the threshold value (resistance, continuity, diode) after the displayed value froze. When the two auto-hold conditions are met again after that, refreshing measured values will stop.



Current Measurement

Measurement function* ¹	Measurement range	Fluctuation range	Threshold value
Auto A AC current DC current	20.00 A range (CM4371-50)	Within 1.00 A	1.00 A
AC+DC current	600.0 A range (CM4371-50, CM4373-50)	Within 12.0 A	12.0 A
	1000 A range (CM4375-50)	Within 12.0 A (When inputting more than 12.0 A) Within 1.0 A (When inputting more than 12.0 A)	12.0 A (When inputting more than 12.0 A) 0.9 A (When inputting more than 12.0 A)
	2000 A range (CM4373-50)	Within 40 A	40 A

37

Current Measurement

Measurement Measurement function*1 range		Fluctuation range	Threshold value	
Auto V* ² AC voltage DC voltage* ² AC+DC voltage	6.000 V, 60.00 V, 600.0 V range	Within 120 counts	120 counts	
ACTDC Vollage	1000 V range	Within 20 V	20 V	
DC High V Probe Mode	600.0 V range	Within 12.0 V	80.0 V	
	2000 V range	Within 20 V	80 V	
Continuity check Resistance	600.0Ω range, $6.000 k\Omega$ range, $60.00 k\Omega$ range, $60.00 k\Omega$ range, $600.0 k\Omega$ range, $6.000 M\Omega$ range	Within 100 counts	4900 counts	
Diode	1.800 V range	Within 0.040 V	1.460 V	


^{*1:} The automatic hold function does not support measurement functions not listed in this row.



^{*2:} Except the 600.0 mV range (only when the range is set manually)

Switching the ranges

When the CM4373-50 measures current




The CM4375-50 provides the 1000 A range only.

39


Current Measurement

Filter function






Maximum value, minimum value, average, and peak value




Current Measurement


Inrush current (inrush)



2.5 Various Other Measurement Functions


Voltage measurement






DC voltage polarity check (p.59)

If the measured value is negative, the buzzer will sound and the display will be backlighted in red. (threshold: -10 V)



Various Other Measurement Functions



45

Various Other Measurement Functions Electric charge Simultaneous display of DC power DC current and DC voltage detection measurement CM4371-50 CM4373-50 e.g., Checking a car battery e.g., Maintenance for a CM4375-50 Switch the ranges using the solar power system See"5.1 Voltage Detection RANGE key. Function" (p. 111) Fn 🖟 0 ADJ A+V / VA Ä+V / VA NCV Ä+V/VÄ NCV Fn Am Fn 🕅 Bring the jaw close a 0 ADJ 0 ADJ power line. 30.0 A (Illuminate in red) To switch the sensitivity. Fn ADJ

(Hi/Lo) (p. 101)

2.6 LCD Backlight, Automatic Power Save (APS)


LCD backlight



Backlight off



Backlight on Automatically shut off after 40 s of inactivity



Set the rotary switch to the OFF position to restart.

47

DC High V Probe Mode

2.7 DC High V Probe Mode

Use of the P2000 DC High Voltage Probe (optional) allows you to measure DC voltage of up to 2000 V (CAT III 2000 V, CAT IV 1000 V), such as open voltage of solar panels.

WARNING

■ Do not use the P2000 to measure AC voltage.



The probe cannot accurately measure AC voltage. Improper measurement could lead to electric shock. You can use the P2000 for DC voltage measurement only.

■ Do not measure voltage that exceeds 2000 V DC.

Doing so could damage the instrument and the P2000, causing bodily injury.



■ Use the P2000 to measure voltage that exceeds 1000 V.

Use of other probes could cause the operator to experience an electric shock.

ACAUTION



■ Connect the instrument and the P2000 together with the strap when using the L4943.

The cables and plugs will be subjected to stress, damaging them.



When using the L4943 Connection Cable Set*

- 1 Disconnect the clip* from the strap buckle* as shown in the figure.
- 3 Attach the strap buckle to the instrument and connect it to the clip that you attached to the P2000 with the strap.



2 Attach the strap* to the P2000.
For details, see the P2000 Instructon manual.



Strap


*: Supplied with the P2000.



When using the L4930 Connection Cable Set or the L4931 Extension Cable Set (optional)

Hang the P2000 in some way, such as using a magnetic strap, not to subject the cables and the plugs to stress.

49



Making Measur


1 Rotate the rotary switch.



2 Hold down the 1 s as des









3 Connect the P200 oltage Probe to the measurement terminals of the instrument.

4 Set t range.





Saving the DC High V Probe mode settings

Turn off the instrument, and then set the rotary switch to other than the OFF position while holding down the two operation keys as described below.



- The DC High V Probe mode start-up setting can be toggled between on and off. (p.59)
- · When the DC High V Probe mode start-up is enabled, the instrument will start in the mode you last used.

51

Wireless communications function

2.8 Wireless communications function

Installing the Z3210 Wireless Adapter (optional) is required. Concurrent use of GENNECT Cross and HID function (p.55) is not available.

Using GENNECT Cross

Enabling the wireless communications function allows you to check and record the measured data of the instrument, and create measurement reports using your mobile device. For details, visit the GENNECT website

Using the wireless communications function

- 1 Connect the Z3210 Wireless Adapter (option) into the instrument. (p. 22)
- Install GENNECT Cross on your mobile device.
- 3 Turn on the instrument.
- 4 Enable the wireless communications function.

When the instrument is turned on for the first time after the Z3210 has been installed, the wireless communications function will be enabled.

Off (Default setting)



) appears:

Wireless communications function enabled

Off: Wireless communications function disabled Hold down for 1 s. Blinks: During wireless communications

Hold down for 1 s



5 Start GENNECT Cross and register the connection of the instrument.

- When GENNECT Cross is started for the first time (when there is no registered instrument), the Instrument Settings screen appears.
- When the instrument is placed near your mobile device, its connection is registered automatically on the Instrument Settings screen of GENNECT Cross (up to eight instruments).
- Wait for 5 to 30 s until the connection of the instrument is registered after turning on the instrument. If the connection of the instrument is not registered after 1 minute has elapsed, restart GENNECT Cross and the instrument.

6 Select a measurement function to perform measurement.

- The communication distance is about 10 m with a clear line of sight. The communicable
 distance may vary greatly depending on the presence of an obstruction (wall or metallic
 shielding object) and the distance between the floor (ground) and instrument. To ensure the
 stable communication, make sure that the radio wave intensity is sufficient.
- GENNECT Cross is free of charge. However, the customer is responsible for the cost to download the application software and connect to the Internet when using the software.
- GENNECT Cross may not operate properly depending on the mobile device.
- The Z3210 uses the 2.4 GHz band wireless technology.
 When there is a device that uses the same frequency band such as a wireless LAN (IEEE 802.11.b/g/n) near your mobile device, the communication may not be established.


When the instrument is placed on the floor or ground, the communication distance becomes shorter. It is recommended that you move the instrument away from the floor or ground and place it on a desk or table or hold it by hand.

53

Wireless communications function

Event recording function

The event recording function logs the data when a measured value exceeds a desired threshold value, which can be set with GENNECT Cross. For details, see the operation guide for the GENNECT Cross app (free of charge). The number of recorded events can be checked using the instrument.



- Up to 99 events can be recorded. If events has reached 99, the event recording will stops.
 When another event recording starts, previously recorded data will be deleted.
- Some events with a duration time of less than 400 ms may not be accurately measured, failing to detect them.*
- * Current frequency, voltage frequency, capacitance (400 ms to 4000 ms, depending on measured value), temperature (type K thermocouple) 2000 ms



Z3210-to-Excel direct data entry function (Excel direct input function, HID function)

Concurrent use of GENNECT Cross and HID function is not available.

The human interface device (HID) profile, with which the Z3210 Wireless Adapter is equipped, is a profile same as that wireless keyboards use.

HID ON	Preparatory to data entry, open an Excel file on your mobile device or computer and choose a cell. When the instrument's display freezes, the measured values will be entered on the cells. The use of this function with the automatic hold function enabled comes in handy. (p.35)
HID OFF	When you wish to use GENNECT Cross, disable the HID function.

The setting whether the HID function has been enabled or disabled will not be saved in the instrument but in the Z3210.



55

Wireless communications function

Confirming the HID setting


- 1 Remove the test leads from the object under measurement.
- 2 Set the rotary switch to the OFF position.
- 3 Connect the Z3210 Wireless Adapter (option) into the instrument. (p.22)
- 4 Confirm the HID setting.

Make sure that the instrument is turned off, and then set the rotary switch to the TEMP position while holding down the $\boxed{\texttt{RANGE}}$ key.



The settings stored in the Z3210 will be displayed.





When [----] appears

Update the Z3210 firmware to the latest version using GENNECT Cross (version 1.8 or later)...

To change the HID setting, use the procedure on the following page. $\label{eq:hilbert}$




Changing the HID setting

- 1 Turn off the instrument.
- 2 Change the HID setting.

Make sure that the instrument is turned off, and then set the rotary switch to any position while holding down both the $\stackrel{\sim}{\mathcal{D}}$ key and the $\stackrel{\sim}{\mathsf{Fn}}$ key.



After exhibiting the following displays, the instrument is automatically turned off.



3 Turn on the instrument again. The HID setting will be toggled.

57

Wireless communications function

IMPORTANT

To switch over from the HID function to GENNECT Cross

If you start GENNECT Cross without canceling the paring between the mobile device and the instrument, GENNECT Cross may not be able to recognize the instrument as a connectible device. Follow the procedure below to reconnect the instrument to GENNECT Cross. Use the **Bluetooth**® setting of your mobile device to delete the instrument.

- 1. Disable the Z3210's HID function. (p.57)
- 2. Use the Instrument Setting of GENNECT Cross to reconnect the instrument.



2.9 Rotary Switch Combinations



<u>Turn off the instrument, and then turn it on again while holding down one or two operation keys.</u>

(Set the rotary switch to other than the OFF position)

Setting	Procedure	Factory- shipped setting	Saving of setting
Auto-power save (APS) function cancel	HOLD + Any position	On	Not saved
DC current/voltage, polarity check on/off	Fn + Any position	Off	Saved
LCD all segments display* ¹ , firmware version number* ¹ , model number (only last four digit)* ¹ , serial number* ¹ , HID setting check (Z3210 required)* ¹	RANGE + (Any position	-	-
Buzzer (on/off)	MAX/MIN + Any position	On	Saved
Automatic backlight shutoff (on/ off)	Any position	On	Saved
DC High V Probe mode setting saving (on/off)	Any position	Off	Saved

59

Rotary Switch Combinations

Setting	Procedure	Factory- shipped setting	Saving of setting
Toggling the HID setting (on/off) (Z3210 required)	禁+Fn+	-	_*2
Switching between the two temperature units: degrees Celsius and degrees Fahrenheit	Fn + HOLD + C MAX/MIN + RANGE Hold To switch the temperature units To save the s MAX/MIN PEAK Hold down for	Degrees Celsius	Saved

^{*1:} The screen display depends on the rotary switch position.



^{*2:} The setting whether the HID function has been enabled or disabled will not be saved in the instrument but in the Z3210.

3

Specifications

3.1 General Specifications

Operating environment	Indoor use, pollution degree 2, altitude up to 2000 m (6562 ft.)
Operating temperature and humidity range	-25°C to 65°C (-13°F to 149°F), 90% RH or less (non-condensing)
Storage temperature and humidity range	-30°C to 70°C (-22°F to 158°F), 90% RH or less (non-condensing, with batteries removed)

61

General Specifications

Dust resistance and water resistance	IP20 (EN 60529) (when measuring voltage with the instrument completely dried and the jaws closed)			
	IP50 (EN 60529) (when measuring resistance under completely dry conditions) IP54 (EN 60529) (in storage)			
	The protection rating for the enclosure of this instrument (based on EN60529) is IP20*, IP50*, or IP54*.			
	* IP20, IP50, IP54:			
	This indicates the degree of protection provided by the enclosure of the device for use in hazardous locations, entry of solid foreign objects, and the ingress of water			
	 Protected against access to hazardous parts with a fingers. The equipment inside the enclosure is protected against entry by solid foreign objects larger than 12.5 mm in diameter. 			
	5: Protected against access to hazardous parts with wire measuring 1.0 mm in diameter. Dustproof type (The penetration of dust cannot be prevented completely, but quantities of dust that may hinder the stated operation of equipment or safety cannot penetrate the enclosure.)			
	0: The equipment inside the enclosure is not protected against the harmful effects of water.			
	4: The equipment inside the enclosure is protected against the harmful effects of water splashed against the enclosure from any direction.			
Standards	Safety EN 61010 EMC EN 61326			

General Specifications

Maximum	CM4371-50	φ33 mm
measurable conductor diameter	CM4373-50	φ55 mm
	CM4375-50	φ34 mm
Weight	CM4371-50	Approx. 340 g (12.0 oz., including batteries)
	CM4373-50	Approx. 530 g (18.7 oz., including batteries)
	CM4375-50	Approx. 350 g (12.3 oz., including batteries)
Product warranty duration	3 years or until	the jaw open/close cycles reaches 30,000, whichever comes first
Accessories	p.7	
Options	p.8	

^{*1:} Other prescribed conditions

64

Input Specifications, Measurement Specifications

3.2 Input Specifications, Measurement Specifications

(1) Basic specifications

See "3.3 Accuracy table" (p.75). 1000 V AC (up to 1 kHz) 1000 V DC	
()	
600 V (measurement category IV) 1000 V (measurement category III) Anticipated transient overvoltage: 8000 V	
True RMS measurement	
COM terminal, V terminal	

(2) Current measurement specifications

Maximum input current	As per the frequency derating characteristics (p.68)		
Coupling type	AC current*1	AC coupling	
	Other current measurement parameters	DC coupling	



When measuring 10 AAC, with the LCD not backlighted, values for reference purposes at 23°C

^{*2:} Other prescribed conditions

When measuring 100 A AC, with the LCD not backlighted, values for reference purposes at 23°C

^{*3:} The Jaw is not included in the dimensions of width and depth but in that of height.

Input Specifications, Measurement Specifications

Display update rate*2	te*2 Auto A, AC current, DC current, AC+DC current		5 times/	's
	Current frequer	Current frequency		.0 times/s (depending on the frequency)
	DC power		1 time/s	
	DC current + DC voltage		2.5 time	es/s
Zero-display range	Auto A, AC curr DC current, AC+DC current	,	5 counts	s or less
Crest factor	Auto A, AC current, AC+DC current, inrush current			
	CM4371-50 20.00 A		range	7.5
		600.0 A range		3 (500.0 A or less) 2.5 (more than 500.0 A but 600.0 A or less)
	CM4373-50	CM4373-50 600.0 A range 2000 A range		3 (500.0 A or less) 2.5 (more than 500.0 A but 600.0 A or less)
				2.84 (1000 A or less) 1.42 (more than 1000 A but 2000 A or less)
	CM4375-50	1000 A range		1.5 (1000 A or less)

66

Input Specifications, Measurement Specifications

Frequency detection	CM4371-50	20.00 A range	4.00 A or more*3
input level		600.0 A range	20.0 A or more
	CM4373-50	600.0 A range	40.0 A or more
		2000 A range	200 A or more
	CM4375-50	1000 A range	5.0 A or more*4
Inrush trigger level	CM4371-50	20.00 A range	+2.0 A or more Otherwise, -2.0 A or less
		600.0 A range	+10 A or more Otherwise, -10 A or less
	CM4373-50	600.0 A range	+10 A or more Otherwise, -10 A or less
		2000 A range	+100 A or more Otherwise, -100 A or less
	CM4375-50 1000 A range +10 A or more Otherwise, −10 A or less		. * =
Peak detection time width	1 ms or more (with filter disabled)		

^{*1:} Does not apply to AC detection in Auto A mode.

CValuetesters.com


^{*2:} Does not include range switching time.

^{*3: 8.00} A or more for 1 Hz \leq f \leq 5 Hz

^{*4: 10.0} A or more for 1 Hz ≤ f ≤ 5 Hz

Frequency derating characteristics


CM4371-50




Inputting up to 1061 A of current is allowable for 1 minute or less. (66 Hz or less)

68

CM4373-50



CM4375-50





Input Specifications, Measurement Specifications

(3) Voltage measurement specifications

Overload protection	1100 V DC, 1100 V AC, or 2 × 10 ⁷ V·Hz, whichever is lower (Up to 1 minute of continuous application)		
Coupling type	AC voltage*1	AC coupling	
	Other voltage measurement parameters	DC coupling	
Input impedance	See "3.3 Accuracy table" (p.75).		
Display update rate*2	Auto V, AC voltage, DC voltage, AC + DC voltage	5 times/s	
	Voltage frequency	0.3 to 5.0 times/s (depending on frequency)	
	DC power	1 time/s	
	DC current + DC voltage	2.5 times/s	
Zero-display range	Auto V, AC voltage, AC voltage + DC voltage	5 counts or less	
Crest factor	Auto V, AC voltage, AC voltage + DC voltage	6.000 V range, 60.00 V range, 600.0 V range: 3 (4000 counts or less) 2 (more than 4000 counts but 6000 counts or less)	
		1000 V range: 2 (750 counts or less) 1.5 (more than 750 counts but 1000 counts or less)	

70

Input Specifications, Measurement Specifications

Peak detection time width	1 ms or more (with filter disabled)		
Frequency detection input level	10% or more of each range's f.s.		
CMRR*3	AC voltage, AC+DC voltage 60 dB or more		
	DC voltage	100 dB or more	
NMRR*4	DC voltage	60 dB or more	

^{*1:} Does not apply to AC detection in Auto V mode.



^{*2:} Does not include range switching time.

^{*3:} Defined for 1 k Ω unbalance assuming that the input frequency is 0 Hz, 50 Hz, or 60 Hz.

^{*4:} Defined assuming that the input frequency is 50 Hz or 60 Hz.

Input Specifications, Measurement Specifications

(4) Other measurement parameters

Overload protection	1000 V DC, 1000 V AC, or 2 × 10 ⁷ V·Hz, whichever is lower (Up to 1 minute of continuous application)		
Overload current	At steady state: 30 mA or less At transient state: 1.5 A or less		
Display update rate*	Capacitance 0.5 to 5 times/s (depending on the capacitance)		
	Temperature (Type K thermocouple)	1 time/s (including thermocouple wiring break check)	
Response time	Continuity check Open or short-circuit condition lasting for 0.5 ms more can be detected.		
Open terminal voltage	Continuity check, resistance, diode 2.0 V DC or less		
Short-circuit detecting threshold	25 Ω ±10 Ω (continuous beep, LCD backlighted in red)		
Open-circuit detecting threshold	250 Ω ±10 Ω		
Stabilization time for reference junction compensation of instrument	Up to 120 minutes (Reference: when the instrument having a temperature of 23°C is left to stand in ambient environments of 65°C for 60 minutes)		

^{*:} Does not include range switching time.

72

Input Specifications, Measurement Specifications

(5) DC High V Probe mode (in combination with the P2000)*1

Maximum rated line-to- ground voltage	Conform to the specifications of the P2000.	
Maximum rated voltage between terminals	Conform to the specifications of the P2000.	
Overload protection	Conform to the specifications of the P2000.	
Coupling type	DC coupling	
Combinatorial measurement accuracy	DC high voltage See "(11) DC high voltage (DC High V Probe mode)" (p.98) in "3.3 Accuracy table." DC power See "(18) DC power" (p.102) in "3.3 Accuracy table."	

^{*1:} The specifications above apply when both of the following two conditions are satisfied only: (1) the P2000 is connected, and (2) the instrument is in DC High V Prove mode.





Input Specifications, Measurement Specifications

(6) Accuracy specifications

Accuracy guarantee conditions	Accuracy guarantee duration	year (duration for which accuracy shown in the accuracy table is guaranteed) years (duration for which 1.5 times accuracy shown in the accuracy table is guaranteed), value for reference purposes	
	Accuracy guarantee temperature and humidity range	23°C ±5°C (73°F ±9°F), 90% RH or less (non-condensing)	
Accuracy guarantee of current measurement, continuity check, and res measurement assumes that zero adjustment has been performed. Temperature (Type K thermocouple) measurement requires use of the			
Input condition for accuracy table	Sine wave input		
Measurement accuracy	See "3.3 Accuracy table" (p.75).		
Effects of	CM4371-50 Within ±1.5%	rdg	
conductor position*	CM4373-50 Within ±1.0% rdg		
position	CM4375-50 Within ±1.5% rdg (for cables of ϕ 11 mm or more)		
Temperature coefficient	Add [(measurement accuracy × 0.1)/°C] to measurement accuracy (outside the temperature range of 23°C ±5°C).		

^{*:} At any position with respect to the jaw's center-point.

74

Accuracy table

3.3 Accuracy table

(1) Auto A (AC/DC current automatic detection)

When AC is detected:

Conforms to the accuracy specifications described in "(4) AC+DC voltage" (p.82).

When DC is detected:

Conforms to the accuracy specifications described in "(3) DC current" (p.80).

(2) AC current

Measured value/MAX/MIN/AVG (CM4371-50)

Range	Accuracy		Measureme	nt accuracy
(automatic ranging threshold)	guarantee range (resolution)	Accuracy guarantee frequency range	Filter disabled	Filter enabled
20.00 A	1.00 A to 20.00 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.10 A	±2.3% rdg ±0.10 A
(more	(0.01 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.08 A	±1.8% rdg ±0.08 A
than 2000 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±0.10 A	_
600.0 A	1.0 A to 600.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.5 A	±2.3% rdg ±0.5 A
(less than	(0.1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.3 A	±1.8% rdg ±0.3 A
180 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±0.5 A	-

CValuetesters.com

Accuracy table

Measured value/MAX/MIN/AVG (CM4373-50)

Range	Accuracy		Measurement accuracy	
(automatic ranging threshold)	guarantee range (resolution)	Accuracy guarantee frequency range	Filter disabled	Filter enabled
600.0 A	1.0 A to 30.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±1.0 A	±2.3% rdg ±1.0 A
(more	(0.1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.8 A	±1.8% rdg ±0.8 A
than 6000		66 Hz < f < 1 kHz	±2.0% rdg ±1.0 A	-
counts) 30.1 A to 600.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.5 A	±2.3% rdg ±0.5 A	
	(0.1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.3 A	±1.8% rdg ±0.3 A
		66 Hz < f < 1 kHz	±2.0% rdg ±0.5 A	-
2000 A	10 A to 1800 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±5 A	±2.3% rdg ±5 A
(less than	(1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±3 A	±1.8% rdg ±3 A
540 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±5 A	-
	1801 A to 2000 A	10 Hz ≤ f < 45 Hz	±2.8% rdg ±5 A	±3.3% rdg ±5 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±2.3% rdg ±3 A	±2.8% rdg ±3 A
		66 Hz < f < 1 kHz	_	-

76

Accuracy table

Measured value/MAX/MIN/AVG (CM4375-50)

	Accuracy	Accuracy guarantee frequency range	Measurement accuracy	
Range	guarantee range (resolution)		Filter disabled	Filter enabled
1000 A	1.0 A to 30.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±1.0 A	±2.3% rdg ±1.0 A
	(0.1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.8 A	±1.8% rdg ±0.8 A
		66 Hz < f < 1 kHz	±2.0% rdg ±1.0 A	-
	30.1 A to 900.0 A (0.1 A)	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.5 A	±2.3% rdg ±0.5 A
		45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.3 A	±1.8% rdg ±0.3 A
		66 Hz < f < 1 kHz	±2.0% rdg ±0.5 A	-
	900.1 A to 999.9 A (0.1 A)	10 Hz ≤ f < 45 Hz	±2.3% rdg ±0.5 A	±2.8% rdg ±0.5 A
		45 Hz ≤ f ≤ 66 Hz	±1.8% rdg ±0.3 A	±2.3% rdg ±0.3 A
		66 Hz < f < 1 kHz	±2.5% rdg ±0.5 A	-

77

Accuracy table

PEAK MAX/ PEAK MIN (CM4371-50)

2 de mos (2 de mos (om-or) os)			
Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
20.00 A	±1.0 A to ±150.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.7 A
	(0.1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±0.7 A
600.0 A	±10 A to ±900 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
	±901 A to ±1500 A	10 Hz ≤ f < 45 Hz	±5.5% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±5.0% rdg ±7 A
		66 Hz < f < 1 kHz	±5.7% rdg ±7 A



PEAK MAX/ PEAK MIN (CM4373-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
600.0 A	±10 A to ±1500 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
2000 A	±10 A to ±2300 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
	±2301 A to ±2840 A	10 Hz ≤ f < 45 Hz	±6.5% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±6.0% rdg ±7 A
		66 Hz < f < 1 kHz	_

PEAK MAX/ PEAK MIN (CM4375-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
1000 A	±10 A to ±1000 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
	±1001 A to ±1500 A	10 Hz ≤ f < 45 Hz	±2.3% rdg ±7 A
	(1 A)	45 Hz ≤ f ≤ 66 Hz	±1.8% rdg ±7 A
		66 Hz < f < 1 kHz	±2.5% rdg ±7 A

79

Accuracy table

(3) DC current

Measured value/MAX/MIN/AVG (CM4371-50)

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Measurement accuracy
20.00 A	±1.00 A to ±20.00 A (0.01 A)	±1.3% rdg ±0.08 A
(more than 2000 counts)		
600.0 A	±1.0 A to ±600.0 A (0.1 A)	±1.3% rdg ±0.3 A
(less than 180 counts)		

Measured value/MAX/MIN/AVG (CM4373-50)

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Measurement accuracy
600.0 A	±1.0 A to ±30.0 A (0.1 A)	±1.3% rdg ±0.8 A
(more than 6000 counts)	±30.1 A to ±600.0 A (0.1 A)	±1.3% rdg ±0.3 A
2000 A	±10 A to ±2000 A (1 A)	±1.3% rdg ±3 A
(less than 540 counts)		

Measured value/MAX/MIN/AVG (CM4375-50)

Range	Accuracy guarantee range (resolution)	Measurement accuracy
1000 A	±1.0 A to ±30.0 A (0.1 A)	±1.3% rdg ±0.8 A
	±30.1 A to ±999.9 A (0.1 A)	±1.3% rdg ±0.3 A



PEAK MAX/ PEAK MIN (CM4371-50)

Range	Accuracy guarantee range (resolution) Measurement accu	
20.00 A	±1.0 A to ±150.0 A (0.1 A)	±1.3% rdg ±0.7 A
600.0 A	±10 A to ±900 A (1 A)	±1.3% rdg ±7 A
	±901 A to ±1500 A (1 A)	±5.0% rdg ±7 A

PEAK MAX/ PEAK MIN (CM4373-50)

Range	Accuracy guarantee range (resolution)	Measurement accuracy
600.0 A	±10 A to ±1500 A (1 A)	±1.3% rdg ±7 A
2000 A	±10 A to ±2300 A (1 A)	±1.3% rdg ±7 A
	±2301 A to ±2840 A (1 A)	±6.0% rdg ±7 A

PEAK MAX/ PEAK MIN (CM4375-50)

Range	Accuracy guarantee range (resolution)	Measurement accuracy
1000 A	±10 A to ±1000 A (1 A)	±1.3 % rdg ±7 A
	±1001 A to ±1500 A (1 A)	±1.8% rdg ±7 A

81

Accuracy table

(4) AC+DC voltage

Measured value/MAX/MIN/AVG (CM4371-50)

Range	Accuracy		Measureme	nt accuracy
(automatic ranging threshold)	guarantee range (resolution)	Accuracy guarantee frequency range	Filter disabled	Filter enabled
20.00 A	1.00 A to 20.00 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.10 A	±2.3% rdg ±0.10 A
(more	(0.01 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.13 A	±1.8% rdg ±0.13 A
than 2000 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±0.10 A	_
600.0 A	1.0 A to 600.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.7 A	±2.3% rdg ±0.7 A
(less than	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±1.3 A	±1.8% rdg ±1.3 A
180 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±0.7 A	_



Measured value/MAX/MIN/AVG (CM4373-50)

Range	Accuracy		Measurement accuracy	
(automatic ranging threshold)	guarantee range (resolution)	Accuracy guarantee frequency range	Filter disabled	Filter enabled
600.0 A	1.0 A to 30.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±1.2 A	±2.3% rdg ±1.2 A
(more than	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±1.8 A	±1.8% rdg ±1.8 A
6000 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±1.2 A	-
	30.1 A to 600.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.7 A	±2.3% rdg ±0.7 A
(0.1 A)	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±1.3 A	±1.8% rdg ±1.3 A
		66 Hz < f < 1 kHz	±2.0% rdg ±0.7 A	-
2000 A	10 A to 1800 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A	±2.3% rdg ±7 A
(less than	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±13 A	±1.8% rdg ±13 A
540 counts)		66 Hz < f < 1 kHz	±2.0% rdg ±7 A	-
	1801 A to 2000 A	10 Hz ≤ f < 45 Hz	±2.8% rdg ±7 A	±3.3% rdg ±7 A
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±2.3% rdg ±13 A	±2.8% rdg ±13 A
		66 Hz < f < 1 kHz	_	_

83

Accuracy table

Measured value/MAX/MIN/AVG (CM4375-50)

	Accuracy	Accuracy guarantee frequency range	Measurement accuracy	
Range	guarantee range (resolution)		Filter disabled	Filter enabled
1000 A	1.0 A to 30.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±1.2 A	±2.3% rdg ±1.2 A
	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±1.8 A	±1.8% rdg ±1.8 A
		66 Hz < f ≤ 1 kHz	±2.0% rdg ±1.2 A	_
	30.1 A to 900.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.7 A	±2.3% rdg ±0.7 A
	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±1.3 A	±1.8% rdg ±1.3 A
		66 Hz < f ≤ 1 kHz	±2.0% rdg ±0.7 A	_
	900.1 A to 999.9 A	10 Hz ≤ f < 45 Hz	±2.3% rdg ±0.7 A	±2.8% rdg ±0.7 A
	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.8% rdg ±1.3 A	±2.3% rdg ±1.3 A
		66 Hz < f ≤ 1 kHz	±2.5% rdg ±0.7 A	_



PEAK MAX/ PEAK MIN (CM4371-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
20.00 A	±1.0 A to ±150.0 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±0.7 A
	(0.1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±0.7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±0.7 A
600.0 A	±10 A to ±900 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
	±901 A to ±1500 A	10 Hz ≤ f < 45 Hz	±5.5% rdg ±7 A
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±5.0% rdg ±7 A
		66 Hz < f < 1 kHz	±5.7% rdg ±7 A

85

Accuracy table

PEAK MAX/ PEAK MIN (CM4373-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
600.0 A	±10 A to ±1500 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
2000 A	±10 A to ±2300 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A
	±2301 A to ±2840 A	10 Hz ≤ f < 45 Hz	±6.5% rdg ±7 A
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±6.0% rdg ±7 A
		66 Hz < f < 1 kHz	_

PEAK MAX/ PEAK MIN (CM4375-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy	
1000 A	±10 A to ±1000 A	10 Hz ≤ f < 45 Hz	±1.8% rdg ±7 A	
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.3% rdg ±7 A	
		66 Hz < f < 1 kHz	±2.0% rdg ±7 A	
	±1001 A to ±1500 A	10 Hz ≤ f < 45 Hz	±2.3% rdg ±7 A	
	(1 A)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.8% rdg ±7 A	
		66 Hz < f < 1 kHz	±2.5% rdg ±7 A	



(5) Current frequency, voltage frequency

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Measurement accuracy
9.999 Hz	1.000 Hz to 9.999 Hz	±0.1% rdg ±0.003 Hz
(more than 9999 counts)	(0.001 Hz)	
99.99 Hz	1.00 Hz to 99.99 Hz	±0.1% rdg ±0.01 Hz
(more than 9999 counts, less than	(0.01 Hz)	
900 counts)		
999.9 Hz	1.0 Hz to 999.9 Hz	±0.1% rdg ±0.1 Hz
(less than 900 counts)	(0.1 Hz)	

(6) Inrush current

Measured inrush value (CM4371-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
20.00 A	3.00 A to 20.00 A (0.01 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±5.0% rdg ±0.13 A
600.0 A	10.0 A to 600.0 A (0.1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±5.0% rdg ±1.3 A

87

Accuracy table

Measured inrush value (CM4373-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
600.0 A	10.0 A to 600.0 A (0.1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±5.0% rdg ±1.3 A
2000 A	100 A to 1800 A (1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±3.3% rdg ±13 A
	1801 A to 2000 A (1 A)	DC, 20 Hz ≤ f ≤ 66 Hz	±5.0% rdg ±13 A

Measured inrush value (CM4375-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
1000 A	10.0 A to 999.9 A (0.1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±5.0% rdg ±1.3 A



Inrush peak value (CM4371-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
20.00 A	±3.0 A to ±150.0 A (0.1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±6.0% rdg ±1.0 A
600.0 A	±10 A to ±900 A (1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±6.0% rdg ±10 A
	±901 A to ±1500 A (1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±9.7% rdg ±10 A

Inrush peak value (CM4373-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
600.0 A	±10 A to ±1500 A (1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±6.0% rdg ±10 A
2000 A	±100 A to ±2300 A (10 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±6.0% rdg ±100 A
	±2310 A to ±2840 A (10 A)	DC, 20 Hz ≤ f ≤ 66 Hz	±8.0% rdg ±100 A

Inrush peak value (CM4375-50)

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range	Measurement accuracy
1000 A	±10 A to ±1000 A (1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±6.0% rdg ±10 A
	±1001 A to ±1500 A (1 A)	DC, 20 Hz ≤ f ≤ 500 Hz	±8.0% rdg ±10 A

89

Accuracy table

(7) Auto V (AC/DC voltage automatic detection)

When AC is detected: Conforms to the accuracy specifications described in "(10) AC+DC voltage" (p.95). When DC is detected: Conforms to the accuracy specifications described in "(9) DC voltage" (p.93).

(8) AC voltage

Measured value/MAX/MIN/AVG

Range	Accuracy		Measureme	nt accuracy	
(automatic ranging threshold)	guarantee range (resolution)	Accuracy guarantee frequency range*1 *2	Filter disabled	Filter enabled	Input impedance* ³
6.000 V	0.000 V to	15 Hz ≤ f < 45 Hz	±1.5% rdg	±2.0% rdg	3.2 MΩ ±5%
(more than	0.299 V		±0.015 V	±0.015 V	
6000 counts)	(0.001 V)	45 Hz ≤ f ≤ 66 Hz	±0.9% rdg	±1.4% rdg	
			±0.013 V	±0.013 V	
		66 Hz < f < 1 kHz	±1.5% rdg		
			±0.015 V	_	
	0.300 V to	15 Hz ≤ f < 45 Hz	±1.5% rdg	±2.0% rdg	3.2 MΩ ±5%
	6.000 V		±0.005 V	±0.005 V	
	(0.001 V)	45 Hz ≤ f ≤ 66 Hz	±0.9% rdg	±1.4% rdg	
			±0.003 V	±0.003 V	
		66 Hz < f < 1 kHz	±1.5% rdg		
			±0.005 V	_	

CValuetesters.com

Range	Accuracy		Measureme	nt accuracy	
(automatic ranging threshold)	guarantee range (resolution)	Accuracy guarantee frequency range*1 *2	Filter disabled	Filter enabled	Input impedance* ³
60.00 V (more than	3.00 V to 60.00 V	15 Hz ≤ f < 45 Hz	±1.5% rdg ±0.05 V	±2.0% rdg ±0.05 V	3.1 MΩ ±5%
6000 counts, less than 540	(0.01 V)	45 Hz ≤ f ≤ 66 Hz	±0.9% rdg ±0.03 V	±1.4% rdg ±0.03 V	
counts)		66 Hz < f < 1 kHz	±1.5% rdg ±0.05 V	_	
600.0 V (more than	30.0 V to 600.0 V	15 Hz ≤ f < 45 Hz	±1.5% rdg ±0.5 V	±2.0% rdg ±0.5 V	3.0 MΩ ±5%
6000 counts, less than 540	(0.1 V)	45 Hz ≤ f ≤ 66 Hz	±0.9% rdg ±0.3 V	±1.4% rdg ±0.3 V	
counts)		66 Hz < f < 1 kHz	±1.5% rdg ±0.5 V	_	
1000 V (less than 540	50 V to 1000 V	15 Hz ≤ f < 45 Hz	±1.5% rdg ±5 V	±2.0% rdg ±5 V	3.0 MΩ ±5%
counts)	(1 V)	45 Hz ≤ f ≤ 66 Hz	±0.9% rdg ±3 V	±1.4% rdg ±3 V	
		66 Hz < f < 1 kHz	±1.5% rdg ±5 V	_	

^{*1:} Accuracy within the frequency range of 15 Hz (inclusive) to 20 Hz (exclusive) is designed values.

91

Accuracy table

PEAK MAX/ PEAK MIN

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range*1 *2	Measurement accuracy
6.000 V	0 V to ±12.00 V	15 Hz ≤ f < 45 Hz	±1.8% rdg ±0.07 V
	(0.01 V)	45 Hz ≤ f ≤ 66 Hz	±1.5% rdg ±0.07 V
		66 Hz < f < 1 kHz	±1.8% rdg ±0.07 V
60.00 V	00 V ±3.0 V to ±120.0 V (0.1 V)	15 Hz ≤ f < 45 Hz	±1.8% rdg ±0.7 V
		45 Hz ≤ f ≤ 66 Hz	±1.5% rdg ±0.7 V
		66 Hz < f < 1 kHz	±1.8% rdg ±0.7 V
600.0 V	±30 V to ±1000 V*3	15 Hz ≤ f < 45 Hz	±1.8% rdg ±7 V
	(1 V)	45 Hz ≤ f ≤ 66 Hz	±1.5% rdg ±7 V
		66 Hz < f < 1 kHz	±1.8% rdg ±7 V
1000 V	±50 V to ±1000 V*4	15 Hz ≤ f < 45 Hz	±1.8% rdg ±7 V
	(1 V)	45 Hz ≤ f ≤ 66 Hz	±1.5% rdg ±7 V
		66 Hz < f < 1 kHz	±1.8% rdg ±7 V

 $^{^{\}star}1$: Accuracy within the frequency range of 15 Hz (inclusive) to 20 Hz (exclusive) is designed values.



^{*2:} Within the frequency range of less than 45 Hz, the accuracy guarantee assumes a superposed DC voltage of less than 500 V.

^{*3:} Defined assuming that the 50 Hz AC is input.

^{*2:} Within the frequency range of less than 45 Hz, the accuracy guarantee assumes a superposed DC voltage of less than 500 V.

^{*3:} Values of up to ±1200 V are displayed, but accuracy is not defined for display values in excess of 1000 V (values for reference purposes).

^{*4:} Values of up to ±1500 V are displayed, but accuracy is not defined for display values in excess of 1000 V (values for reference purposes).

(9) DC voltage

Measured value/MAX/MIN/AVG

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Measurement accuracy	Input impedance (DC input)
600.0 mV	0.0 mV to ±600.0 mV	±0.5% rdg	6.7 MΩ ±5%
(more than 6000 counts)	(0.1 mV)	±0.5 mV	
6.000 V	0.000 V to ±6.000 V	±0.5% rdg	6.7 MΩ ±5%
(more than 6000 counts,	(0.001 V)	±0.003 V	
less than 540 counts)			
60.00 V	0.00 V to ±60.00 V	±0.5% rdg	6.1 MΩ ±5%
(more than 6000 counts,	(0.01 V)	±0.03 V	
less than 540 counts)			
600.0 V	0.0 V to ±600.0 V	±0.5% rdg	6.0 MΩ ±5%
(more than 6000 counts,	(0.1 V)	±0.3 V	
less than 540 counts)			
1000 V	0 V to ±1000 V	±0.5% rdg	6.0 MΩ ±5%
(less than 540 counts)	(1 V)	±3 V	

93

Accuracy table

PEAK MAX/ PEAK MIN

Range	Accuracy guarantee range (resolution)	Measurement accuracy
600.0 mV	0 mV to ±1200 mV	±1.0% rdg ±7 mV
	(1 mV)	
6.000 V	0.00 V to ±12.00 V	±1.0% rdg ±0.07 V
	(0.01 V)	
60.00 V	0.0 V to ±120.0 V	±1.0% rdg ±0.7 V
	(0.1 V)	
600.0 V	0 V to ±1000 V	±1.0% rdg ±7 V
	(1 V)	
1000 V	0 V to ±1000 V	±1.0% rdg ±7 V
	(1 V)	_



(10) AC+DC voltage

Measured value/MAX/MIN/AVG

Range	Accuracy	Accuracy	Measureme	ent accuracy	
(automatic ranging threshold)	guarantee range (resolution)	guarantee frequency range*1	Filter disabled	Filter enabled	Input impedance*2
6.000 V (more than 6000	0.000 V to 0.299 V	10 Hz ≤ f < 45 Hz	±1.5% rdg ±0.023 V	±2.0% rdg ±0.023 V	DC: 6.7 MΩ ±5% AC: 3.2 MΩ ±5%
counts)	(0.001 V)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±0.023 V	±1.5% rdg ±0.023 V	
		66 Hz < f < 1 kHz	±1.5% rdg ±0.023 V	-	
	0.300 V to 6.000 V	10 Hz ≤ f < 45 Hz	±1.5% rdg ±0.013 V	±2.0% rdg ±0.013 V	DC: 6.7 MΩ ±5% AC: 3.2 MΩ ±5%
	(0.001 V)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±0.013 V	±1.5% rdg ±0.013 V	
		66 Hz < f < 1 kHz	±1.5% rdg ±0.013 V	_	
60.00 V (more than	3.00 V to 60.00 V	10 Hz ≤ f < 45 Hz	±1.5% rdg ±0.13 V	±2.0% rdg ±0.13 V	DC: 6.1 MΩ ±5% AC: 3.1 MΩ ±5%
6000 counts, less than 540	(0.01 V)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±0.13 V	±1.5% rdg ±0.13 V	
counts)		66 Hz < f < 1 kHz	±1.5% rdg ±0.13 V	-	

95

Accuracy table

Range	Accuracy	Accuracy	Measuremer	nt accuracy	
(automatic ranging threshold)	guarantee range (resolution)	guarantee frequency range*1	Filter disabled	Filter enabled	Input impedance*2
600.0 V	30.0 V to	10 Hz ≤ f < 45 Hz	±1.5% rdg	±2.0% rdg	DC: 6.0 MΩ ±5%
(more than	600.0 V		±0.7 V	±0.7 V	AC: 3.0 MΩ ±5%
6000 counts,	(0.1 V)	DC,	±1.0% rdg	±1.5% rdg	
less than 540		45 Hz ≤ f ≤ 66 Hz	±0.7 V	±0.7 V	
counts)		66 Hz < f < 1 kHz	±1.5% rdg	-	
			±0.7 V		
1000 V	50 V to	10 Hz ≤ f < 45 Hz	±1.5% rdg	±2.0% rdg	DC: 6.0 MΩ ±5%
(less than 540	1000 V		±7 V	±7 V	AC: 3.0 MΩ ±5%
counts)	(1 V)	DC,	±1.0% rdg	±1.5% rdg	
		45 Hz ≤ f ≤ 66 Hz	±7 V	±7 V	
		66 Hz < f < 1 kHz	±1.5% rdg ±7 V	-	

^{*1:} Accuracy within the frequency range of 10 Hz (inclusive) to 20 Hz (exclusive) is designed values.



^{*2:} Defined assuming that the DC or 50 Hz AC is input.

PEAK MAX/ PEAK MIN

Range	Accuracy guarantee range (resolution)	Accuracy guarantee frequency range*1	Measurement accuracy
6.000 V	0.00 V to ±12.00 V	10 Hz ≤ f < 45 Hz	±1.5% rdg ±0.07 V
	(0.01 V)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±0.07 V
		66 Hz < f < 1 kHz	±1.5% rdg ±0.07 V
60.00 V	00 V ±3.0 V to ±120.0 V (0.1 V)	10 Hz ≤ f < 45 Hz	±1.5% rdg ±0.7 V
		DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±0.7 V
		66 Hz < f < 1 kHz	±1.5% rdg ±0.7 V
600.0 V	±30 V to ±1000 V*2	10 Hz ≤ f < 45 Hz	±1.5% rdg ±7 V
	(1 V)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±7 V
		66 Hz < f < 1 kHz	±1.5% rdg ±7 V
1000 V	±50 V to ±1000 V*3	10 Hz ≤ f < 45 Hz	±1.5% rdg ±7 V
	(1 V)	DC, 45 Hz ≤ f ≤ 66 Hz	±1.0% rdg ±7 V
		66 Hz < f < 1 kHz	±1.5% rdg ±7 V

^{*1:} Accuracy within the frequency range of 10 Hz (inclusive) to 20 Hz (exclusive) is designed values.

97

Accuracy table

(11) DC high voltage (DC High V Probe mode)

Measured value/MAX/MIN/AVG

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Measurement accuracy (In combination with the P2000)	Input impedance (In combination with the P2000)
600.0 V	80.0 V to ±600.0 V	±1.0% rdg ±0.3 V	19.3 MΩ ±2%
(more than 6000 counts)	(0.1 V)		
2000 V	80 V to ±2000 V	±1.0% rdg ±3 V	19.3 MΩ ±2%
(less than 540 counts)	(1 V)		

(12) Continuity check

Range	Accuracy guarantee range (resolution)	Measurement current	Measurement accuracy
600.0 Ω	$0.0~\Omega$ to $600.0~\Omega$ $(0.1~\Omega)$	200 μA ±20%	±0.7% rdg ±0.5 Ω



^{*2:} Values of up to ±1200 V are displayed, but accuracy is not defined for display values in excess of 1000 V (values for reference purposes).

^{*3:} Values of up to ±1500 V are displayed, but accuracy is not defined for display values in excess of 1000 V (values for reference purposes).

(13) Resistance

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Measurement current	Measurement accuracy
600.0 Ω	0.0 Ω to 600.0 Ω	200 µA ±20%	±0.7% rdg
(more than 6000 counts)	(0.1 Ω)		±0.5 Ω
6.000 kΩ	0.000 kΩ to 6.000 kΩ	100 μA ±20%	±0.7% rdg
(more than 6000 counts, less than 540 counts)	(0.001 kΩ)		±0.005 kΩ
60.00 kΩ	0.00 kΩ to 60.00 kΩ	10 μA ±20%	±0.7% rdg
(more than 6000 counts, less than 540 counts)	(0.01 kΩ)		±0.05 kΩ
600.0 kΩ	0.0 kΩ to 600.0 kΩ	1 μA ±20%	±0.7% rdg
(more than 6000 counts, less than 540 counts)	(0.1 kΩ)		±0.5 kΩ
6.000 MΩ	0.000 MΩ to 6.000 MΩ	100 nA ±20%	±1.0% rdg
(less than 540 counts)	(0.001 MΩ)		±0.005 MΩ

(14) Diode

Range	Accuracy guarantee range (resolution)	Short-circuit current	Measurement accuracy
1.800 V	0.000 V to 1.800 V*1 (0.001 V)	200 μA ±20%	±0.7% rdg ±0.005 V

^{*1:} A series of beeps indicates forward connection (0.15 V to 1.8 V). A continuous beep is emitted and the LCD is backlighted in red if the voltage is less than 0.15 V.

99

Accuracy table

(15) Capacitance

Range (automatic ranging threshold)	Accuracy guarantee range (resolution)	Charging current	Measurement accuracy
1.000 μF	0.000 μF to 1.100 μF	10 nA ±20%	±1.9% rdg
(more than 1100 counts)	(0.001 µF)	100 nA ±20%	±0.005 µF
		1 μA ±20%	
10.00 μF	0.00 μF to 11.00 μF	100 nA ±20%	±1.9% rdg
(more than 1100 counts,	(0.01 μF)	1 μA ±20%	±0.05 µF
less than 100 counts)		10 μA ±20%	
100.0 μF	0.0 μF to 110.0 μF	1 μA ±20%	±1.9% rdg
(more than 1100 counts,	(0.1 µF)	10 μA ±20%	±0.5 µF
less than 100 counts)		100 μA ±20%	
1000 μF	0 μF to 1100 μF	10 μA ±20%	±1.9% rdg
(less than 100 counts)	(1 μF)	100 µA ±20%	±5 µF
		200 μA ±20%	

(16) Temperature (Type K thermocouple)

Thermocouple type	Unit	Accuracy guarantee range (resolution)	Measurement accuracy*1
K	°C	-40.0°C to 400.0°C (0.1°C)	±0.5% rdg ±3.0°C
K	°F*2	-40.0°F to 752.0°F (0.1°F)	±0.5% rdg ±5.4°F

^{*1:} Prescribed conditions (assuming that an ambient temperature where the instrument is left to stand stabilizes in the range of ±1°C)



^{*2:} The temperature unit can be switched over to Fahrenheit by a special operation on the instrument.

(17) Electric charge detection (CM4371-50, CM4373-50)

Range (detection sensitivity)	Detectable voltage range*1	Detectable frequency
Hi	Line-to-earth voltage: 40 V AC to 600 V AC	50 Hz/60 Hz
Lo	Line-to-earth voltage: 80 V AC to 600 V AC	50 Hz/60 Hz

^{*1:} Prescribed condition

Assuming that the instrument is brought into contact with a 2 mm² 600 V polyvinyl chloride insulated wire or equivalent

101

Accuracy table

(18) DC power (CM4371-50)

Current range	Voltage range* ¹ (input voltage range)	Accuracy guarantee range (resolution)	Measurement accuracy
20 A	600.0 mV (0.0 mV to ±600.0 mV)	0.00 VA to ±12.00 VA (0.01 VA)	±2.0% rdg ±0.20 VA
	6.000 V (±0.540 V to ±6.000 V)	0.0 VA to ±120.0 VA (0.1 VA)	±2.0% rdg ±2.0 VA
	60.00 V (±5.40 V to ±60.00 V)	0.000 kVA to ±1.200 kVA (0.001 kVA)	±2.0% rdg ±0.020 kVA
	600.0 V (±54.0 V to ±600.0 V)	0.00 kVA to ±12.00 kVA (0.01 kVA)	±2.0% rdg ±0.20 kVA
	1000 V (±540 V to ±1000 V)	0.00 kVA to ±20.00 kVA (0.01 kVA)	±2.0% rdg ±0.20 kVA
DC High V Probe mode	600.0 V (±80.0 V to ±600.0 V)	0.00 kVA to ±12.00 kVA* ² (0.01 kVA)	±3.0% rdg ±0.20 kVA
	2000 V (±540 V to ±2000 V)	0.00 kVA to ±40.00 kVA (0.01 kVA)	±3.0% rdg ±0.20 kVA



Accuracy table

Current range	Voltage range* ¹ (input voltage range)	Accuracy guarantee range (resolution)	Measurement accuracy
600 A	600.0 mV (0.0 mV to ±600.0 mV)	0.0 VA to ±360.0 VA (0.1 VA)	±2.0% rdg ±2.0 VA
	6.000 V (±0.540 V to ±6.000 V)	0.000 kVA to ±3.600 kVA (0.001 kVA)	±2.0% rdg ±0.020 kVA
	60.00 V (±5.40 V to ±60.00 V)	0.00 kVA to ±36.00 kVA (0.01 kVA)	±2.0% rdg ±0.20 kVA
	600.0 V (±54.0 V to ±600.0 V)	0.0 kVA to ±360.0 kVA (0.1 kVA)	±2.0% rdg ±2.0 kVA
	1000 V (±540 V to ±1000 V)	0 kVA to ±600 kVA (1 kVA)	±2.0% rdg ±20 kVA
DC High V Probe mode	600.0 V (±80.0 V to ±600.0 V)	0.00 kVA to ±360.0 kVA* ² (0.1 kVA)	±3.0% rdg ±2.0 kVA
	2000 V (±540 V to ±2000 V)	0.00 kVA to ±1200 kVA (1 kVA)	±3.0% rdg ±20 kVA

103

Accuracy table

DC power (CM4373-50)

С	urrent range	Voltage range* ¹ (input voltage range)	Accuracy guarantee range (resolution)	Measurement accuracy
60	0 A	600.0 mV (0.0 mV to ±600.0 mV)	0.0 VA to ±360.0 VA (0.1 VA)	±2.0% rdg ±2.0 VA
		6.000 V (±0.540 V to ±6.000 V)	0.000 kVA to ±3.600 kVA (0.001 kVA)	±2.0% rdg ±0.020 kVA
		60.00 V (±5.40 V to ±60.00 V)	0.00 kVA to ±36.00 kVA (0.01 kVA)	±2.0% rdg ±0.20 kVA
		600.0 V (±54.0 V to ±600.0 V)	0.0 kVA to ±360.0 kVA (0.1 kVA)	±2.0% rdg ±2.0 kVA
		1000 V (±540 V to ±1000 V)	0 kVA to ±600 kVA (1 kVA)	±2.0% rdg ±20 kVA
	DC High V Probe mode	600.0 V (±80.0 V to ±600.0 V)	0.00 kVA to ±360.0 kVA* ² (0.1 kVA)	±3.0% rdg ±2.0 kVA
		2000 V (±540 V to ±2000 V)	0.00 kVA to ±1200 kVA (1 kVA)	±3.0% rdg ±20 kVA



Accuracy table

Current range	Voltage range*1 (input voltage range)	Accuracy guarantee range (resolution)	Measurement accuracy
2000 A	600.0 mV	0.000 kVA to ±1.200 kVA	±2.0% rdg ±0.020 kVA
	(0.0 mV to ±600.0 mV)	(0.001 kVA)	
	6.000 V	0.00 kVA to ±12.00 kVA	±2.0% rdg ±0.20 kVA
	(±0.540 V to ±6.000 V)	(0.01 kVA)	
	60.00 V	0.0 kVA to ±120.0 kVA	±2.0% rdg ±2.0 kVA
	(±5.40 V to ±60.00 V)	(0.1 kVA)	-
	600.0 V	0 kVA to ±1200 kVA	±2.0% rdg ±20 kVA
	(±54.0 V to ±600.0 V)	(1 kVA)	-
	1000 V	0 kVA to ±2000 kVA	±2.0% rdg ±20 kVA
	(±540 V to ±1000 V)	(1 kVA)	-
DC High V	600.0 V	0.00 kVA to ±1200 kVA*2	±3.0% rdg ±20 kVA
Probe mode	(±80.0 V to ±600.0 V)	(1 kVA)	
	2000 V	0.00 kVA to ±4000 kVA	±3.0% rdg ±20 kVA
	(±540 V to ±2000 V)	(1 kVA)	

105

Accuracy table

DC power (CM4375-50)

Current range	Voltage range*1 (input voltage range)	Accuracy guarantee range (resolution)	Measurement accuracy
1000 A	600.0 mV (0.0 mV to ±600.0 mV)	0.000 kVA to ±0.600 kVA (0.001 kVA)	±2.0% rdg ±0.020 kVA
	6.000 V (±0.540 V to ±6.000 V)	0.00 kVA to ±6.00 kVA (0.01 kVA)	±2.0% rdg ±0.20 kVA
	60.00 V (±5.40 V to ±60.00 V)	0.0 kVA to ±60.0 kVA (0.1 kVA)	±2.0% rdg ±2.0 kVA
	600.0 V (±54.0 V to ±600.0 V)	0 kVA to ±600 kVA (1 kVA)	±2.0% rdg ±20 kVA
	1000 V (±540 V to ±1000 V)	0 kVA to ±1000 kVA (1 kVA)	±2.0% rdg ±20 kVA
DC High V Probe mode	600.0 V (±80.0 V to ±600.0 V)	0 kVA to ±600 kVA* ² (1 kVA)	±3.0% rdg ±20 kVA
	2000 V (±540 V to ±2000 V)	0 kVA to ±2000 kVA (10 kVA)	±3.0% rdg ±20 kVA

^{*1:} DC power ranges will be automatically switched in sync with the voltage range.
*2: When a voltage of less than 80.0 V is input, the LCD shows [- - - -kVA].



4

Maintenance and Service

4.1 Troubleshooting

Problem	Cause	Remedy
The instrument is indicating an abnormal measured value.	The measured value is lower than the lower limit value of the measuring range.	Wrap the wire around the jaw one or more times. Wrapping the wire n times can increase the displayed value by $(n + 1)$ times.
	The tips of the jaw open.	Close the jaw tips.
	The jaw is damaged.	The instrument with its jaw damaged cannot measure current accurately. Have the instrument repaired.
	Displayed values can frequently fluctuate due to induction potential even with no input. This, however, is not a malfunction.	
Measured value differ from those of another clamp-on current meter.	Measured waveforms contain a component that falls outside the frequency characteristics range.	The instrument cannot accurately measure waveforms that contain a component that falls outside the frequency characteristics range.
	The instrument, which uses the true RMS method, can accurately measure distorted waveforms. When measuring a distorted waveform, the measured value will differ from a clamp-on current meter that uses the averaging method.	

107

Troubleshooting

Problem	Cause	Remedy
The current value is larger than expected. A current value is displayed even with no input.	There is a transformer or high- current circuit that emits a strong magnetic field near the instrument. Otherwise, there is a wireless device that emits a strong electric field.	Perform measurement keeping the instrument away from such equipment.
The instrument's jaw emits sound (vibration).	Greater than or equal to 500 A of AC current is being measured.	The jaw may emit sound (vibration); however, there is no effect on the measurement.
The measured value does not appear.	The test leads have a break.	Check the continuity of the test leads. (p.44) If a break is found, replace the test leads.
No measured value is displayed even when the test lead tips are shorted.	The test leads are not inserted all the way.	Insert the test leads all the way.
Zero adjustment is impossible.	Zero adjustment was performed leaving the instrument clamped around a measurement target.	If you wish to measure current, remove the instrument from a measurement target to perform zero adjustment.

If problems cannot be resolved even after you have implemented such remedies, have the instrument repaired.



4.2 Error and Operation Displays

Error display	Description	Remedy
v.UP	The instrument's firmware is being upgraded.	Do not remove the batteries until the upgrade completes.
Err 001	ROM error (program)	When the error appears on the display, it is
Err 002	ROM error (adjustment data)	
Err 004	Memory error	necessary to repair the instrument. Please contact your authorized Hioki distributor or
Err 005	ADC error (hardware malfunction)	reseller.
Err 008	Z3210 communication error (the Z3210 is malfunctioning or is not properly connected)	Perform the following steps. (p.26) Disconnect and then reconnect the Z3210. If you have another Z3210, replace the unit in question with that one. If the error continues to be displayed, the instrument needs to be repaired. Please contact your authorized Hioki distributor or reseller.

109

Cleaning

4.3 Cleaning

ACAUTION



If the instrument becomes dirty, wipe the instrument clean with a soft cloth moistened with water or a neutral detergent.

Never use solvents such as benzene, alcohol, acetone, ether, ketone, thinners or gasoline. Doing so could deform and discolor the instrument.

IMPORTANT

■ Keep the facing core surfaces of the jaws clean by gently wiping them with a soft dry cloth.

Dirt on the facing core surfaces of the jaws can adversely affect the measurement accuracy.

Wipe the LCD gently with a soft, dry cloth.



5

Appendix

5.1 Voltage Detection Function

Check the instrument for proper operation by measuring a power supply with a known voltage, such as a commercial power supply, before use.

The voltage detection function cannot operate correctly for the following circuits and wires:

- Non-grounded circuits, of which the line-to-earth voltage is not fixed, such as the secondary side of transformers
- · DC circuits
- · Grounded wires
- · Shielded wires

It is recommended that you set the voltage detection function to Hi. If the voltage detection function malfunctions due to the effect of a nearby wire, set the sensitivity to Lo. However, depending on the use environment, the instrument with the sensitivity set to Lo may not be able to detect even a voltage within the detection range.

111

Ground


Voltage Detection Function

Measurement principle

The instrument employs a voltage-detecting method using electrostatic coupling to determine the live condition of objects under test.

See"(17) Electric charge detection (CM4371-50, CM4373-50)" (p. 101) for information about the detectable voltage range and detectable frequency.

under test



Measuring principle diagram

Detecting plate Electrode

Equivalent circuit diagram

Detector

Body

Although a detected current will flow to the ground through your body, the current, less than 1 μ A, will not adversely affect you.

IMPORTANT

If it is difficult to judge with the voltage detection function, check the voltage using the voltage measuring function.




5.2 Example of Use

Checking for noise superimposed on DC voltage and current

Measure voltage/current values and voltage/current peak values of each DC component, AC component, and AC+DC resultant component.

Example: A DC voltage of 100 V with an AC voltage of 10 V superimposed



113

Index

<u>A</u>	D
AC+DC current	DC current 37, 46 DC High V Probe mode 48 DC power 46 DC voltage 38, 46, 59, 93 Degrees Fahrenheit 60 Diode 38, 44, 99 Displayed value fluctuation 107 DT4910 Thermocouples (K) 45
Backlight 24, 47, 59 Flashing 43 Illuminate in red 34, 44 Buzzer 24, 34, 43, 59	Error and Operation Display
С	<u>F</u>
Capacitance	Filter



Index	
G	N
GENNECT Cross 52	Noise 40
Н	P
HID 55	Peak value
1	Folanty Check 34, 43, 39
Inrush current	R
	Range
<u>J</u>	Resistance
Jaws 15, 20	•
L	<u>S</u>
L9300	Serial number
М	<u>T</u>
Manual hold 35 Maximum value 41 Measurement function 19, 37, 43 Minimum value 41	Temperature
116	

Index

117

Illuex